

Annexure C


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.: 1929/SFTL

Dated: 24/08/2026

It is certified that an inspection team headed by Food Analyst, State Food Testing Laboratory, Bhubaneswar, Odisha inspected Manjari Devi Public School, Puana Padhan, Balakati, Bhubaneswar 3rd August, 2026 and on the basis of Water Test Report (Attached) bearing No. 1928/SFTL, dated: 24/08/2026 of State Food Testing Laboratory, Bhubaneswar certified that Manjari Devi Public School has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 23/08/2027.



**State Food Testing Laboratory
Convent Square, Kharvel Nagar,
Bhubaneswar, Odisha, 751001**

To

The Principal
Manjari Devi Public School
Purana Padhan, Balakati,
Bhubaneswar – 752 100

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

STATE FOOD TESTING LABORATORY, BHUBANESWAR
Convent Square, Kharvel Nagar, Bhubaneswar, Odisha-751001

No. 1928/SFTL, Bhubaneswar, the 24 th 08 2026

To

The Principal
Manjari Devi Public School,
Purna Pradhan, Balakati Bhubaneswar.

Sub: - Analysis report of Water sample.

Report No.	Nature/Name of sample submitted for analysis	Collected/Sent by	Reference No.& Date of Receipt
1153/26	Bore well Water	A.Biswal	Dt. of Receipt- 03.08.2026

ANALYSIS REPORT

The Sample of Water falling under Regulation No. 2.10.9 of Food Safety and Standards (Food Products and Food Additive) Regulations, 2011 received on 03.08.26 has been caused to be analyzed and the findings are as under:-

i) Sample Description-Bore well water

ii) Physical Appearance: - Water, Dirt & foreign Matter: - Nil, Other visible contaminants: -Nil

Sl. No.	Quality characteristics	Name of method of test used	Result	Prescribed standards as per a. As per provisions of the Act, and the rules and regulations made there under b. As per label declaration for proprietary food
1.	Colour	FSSAI	Agreeable	5 Hazen Units
2.	Odour	Manual	Agreeable	Agreeable
3.	Taste		----	Agreeable
4.	Turbidity		Nil	1 NTU (Max.)
5.	pH		6.7	6.5-8.5
6.	Nitrates (as NO ₃)		Nil	Not more than 45 mg/lit.
7.	Nitrites (as NO ₂)		Nil	Not more than 0.02 mg/lit.
8.	Iron (as Fe)		Nil	Not more than 0.3 mg/lit.
9.	Chloride (as Cl)		38 mg/lit	Not more than 250 mg/lit.
10.	Residual Free chlorine		Nil	Not more than 0.2 mg/lit.
11.	Sulphate (as SO ₄)		Nil	Not more than 200 mg/lit.
12.	Total Alkalinity (as HCO ₃)		38 mg/lit	Not more than 600 mg/lit.
13.	Total Hardness (as CaCO ₃)		38 mg/lit	Not more than 600 mg/lit.
14.	Total Dissolved Solids		195 mg/lit	Not more than 500 mg/lit.
15.	MPN of coliform group of organisms per 100ml		Absent	Absent
16.	Test for E.Coli		Negative	Negative

Remarks: The water sample is safe u/s 3.1(zz) of FSSAct, 2006

Dated: 24/08/2026
State Food Testing Laboratory
Bhubaneswar-1


Food Analyst
GOVT. OF Odisha
Govt. of Odisha